

COMMISSIONERS
MIKE GLEASON- Chairman
WILLIAM MUNDELL
JEFF HATCH-MILLER
KRISTIN K. MAYES
GARY PIERCE

ORIGINAL



0000067594

RECEIVED


060

ARIZONA CORPORATION COMMISSION 2007 MAR -21 P 4: 03

AZ CORP COMMISSION
DOCUMENT CONTROL

March 2, 2007
Arizona Corporation Commission
DOCKETED

MAR -2 2007



Robert W. Geake
Vice President and General Counsel
Arizona Water Company
P.O.Box 29006
Phoenix, Arizona 85038-9006

RE: Arizona Water Company – Application for Extension of its Certificate of Convenience and Necessity (CC&N) Docket No. W-01445A-07-0018
INSUFFICIENCY LETTER #2

Dear Sir:

In reference to the above mentioned application filed on January 11, 2007, and the supporting documents filed on February 21, 2007, this letter is to inform you that the application still has not met the sufficiency requirements as outlined in the Arizona Administrative Code. The deficiency is:

1. In the February 21, 2007 Response to Staff's Insufficiency Letter ("Response"), Arizona Water Company ("AWC") stated that the requested area is adjacent to the City of Sierra Vista wastewater treatment plant. AWC also stated in its Response that it only needs to install a 2" service connection in order to serve the requested area,. Will AWC install a backflow preventor device in this requested area? Please explain.
2. In its Response, AWC indicated that the requested area is plotted for a new "animal control" facility. Does the City have special permit requirements for this requested area? Please explain.
3. According to the Arizona Department of Environmental Quality's Bulletin No.12, 15 gallons per day per animal in dog kennel facility is used to project wastewater flows. Please provide the projected number of gallons of water that would be consumed by this facility?
4. AWC owns and operates eight wells in its Sierra Vista system. Please explain why only seven arsenic sample results were attached to the February 21, 2007 Response to Staff's Insufficiency Letter. Could one of the eight wells not be in service? If so, please indicate which well. If not, please indicate which POE associates with which well(s).


Staff would like to use this opportunity to bring the following to your attention:

Arizona Water Company (Docket No. W-01445A-07-0018)
Insufficiency Letter
3/2/2007
Page 2 of 2

- Pursuant to the Arizona Administrative Code ("A.A.C.") R-14-2-411(C), the time-frame for administrative completeness review shall be suspended from the time the notice of deficiency is issued until staff determines that the application is complete. Upon meeting sufficiency requirements, the Commission has 150 calendar days for its substantive review. This includes conducting a hearing and preparing Opinion and Order to present to the Commission at an Open Meeting; and

If you have any questions concerning this matter, please do not hesitate to contact me at 602-542-0840, Dorothy Hains at 602-542-7274.

Very truly yours,



Blessing N. Chukwu
Executive Consultant III

BNC

cc: Docket Control
Del Smith
Lyn Farmer
Brian Bozzo
Vicki Wallace